



To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Project: 23/27-003 JDD 007

Barr staff has inspected construction sites in the Nine Mile Creek Watershed District for conformance to erosion and sediment control policies. Listed below are construction projects and the improvement needed for effective erosion control. The sites were inspected from May 28, through June 1, 2018.

Site Inspections

2018-65	Sidewalk Construction	May 28, 2018
	Prairie Center Drive	Construction not started. Utility flag locales in place.
	Prairie Lakes Drive	Construction not started.
	Anderson Lakes Parkway	Construction not started.
	Anderson Way	Construction not started.
2018-64	Sidewalk Construction: Valley View Road	May 29, 2018
	Construction not started.	
2018-62	Home Addition: 8272 York Avenue	May 31, 2018
	Site excavation in progress. Perimeter silt fence and original driveway construction entrance in good condition. No site issues.	
2018-60	Home Addition: 5127 Skyline Drive	June 1, 2018
	Construction not started.	
2018-58	Pool Construction: 7710 Marth Court	May 30, 2018
	Construction not started.	
2018-55	Parking Lot Mill & Overlay: 5421 Feltl Road	May 29, 2018
	Construction not started.	
2018-53	Home Construction: 5130 Ridge Trail	May 30, 2018
	Construction not started. Perimeter silt fence installed.	
2018-51	Bloomington Mill & Overlay: 78th Street Area	May 31, 2018
	Construction not started.	

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 2

2018-50	Bloomington Mill & Overlay: Brookside Area Construction not started.	May 31, 2018
2018-49	NE Penn Stormwater Storage Project Construction not started.	May 31, 2018
2018-47	Woodhill Road Reconstruction Sections of street under construction. BMPs installed in areas of current construction. No erosion-related issues observed.	May 28, 2018
2018-45	CenterPoint Energy: Griffit Street Replacement Construction not started.	May 30, 2018
2018-44	CenterPoint Energy: MBLSE Nicollet Project Construction not started.	May 31, 2018
2018-43	Home Reconstruction: 6237 Knoll Drive Home construction in progress. Spoils pile on site. Perimeter silt fence and original concrete driveway in place. No site issues.	May 30, 2018
2018-42	Drury Hotel: Bloomington Construction not started.	May 31, 2018
2018-41	Acorn Mini Storage: Bloomington Building renovations in progress. No site issues.	May 31, 2018
2018-40	Glen Lake Elementary Parking Lot Construction Construction not started.	May 28, 2018
2018-39	Mill & Overlay: 11th Avenue South Construction not started.	May 29, 2018
2018-38	Home Additional: 6301 Westwood Ct. Small excavation on site. No current construction activity.	May 30, 2018
2018-37	Home Construction: 6104 Westridge Boulevard Site excavation in progress. Large soil stockpile on site. Perimeter biologs, inlet protection, and existing driveway construction entrance in place.	June 1, 2018
2018-36	108th Street Construction not started.	May 31, 2018
2018-35	James Avenue Construction not started.	May 31, 2018

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 3

2018-34	86th Street Construction not started.	May 31, 2018
2018-33	Girard Avenue Construction not started.	May 31, 2018
2018-32	Sherwood Circle Construction not started.	May 31, 2018
2018-31	Uptown Circle Construction not started.	May 31, 2018
2018-30	Palmer Rd. Construction not started.	May 30, 2018
2018-28	Edina Street Mill and Overlay Projects	
	a) Presidents C: Construction not started	May 30, 2018
	b) Presidents D: Construction not started	May 30, 2018
	c) Fox Meadow: Construction not started	May 30, 2018
	d) Countryside C: Construction not started	May 30, 2018
	e) Indian Hills D: Construction not started	May 30, 2018
	f) Valley View Rd: Construction not started	June 1, 2018
	g) West 66th St: Construction not started	June 1, 2018
	h) Braemar Hills D: Construction not started	May 29, 2018
	i) West 70th Street: Construction not started	June 1, 2018
	j) Cahill Road: Construction not started	June 1, 2018

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 4

	k) Cahill A: Construction not started	May 30, 2018
	l) Bush Lake Road: Construction not started	May 30, 2018
	m) Edina Industrial/Normandale: Construction not started	May 30, 2018
	n) Normandale Rd/Pentagon: Construction not started	May 30, 2018
	o) Edinborough A & B: Construction not started	May 31, 2018
2018-27	Home Construction: 6453 McCauley Terrace Site excavation in progress. <i>Perimeter silt fence needs to be installed between on-site large soil stockpiles and undisturbed slopes.</i> Rock construction in good condition. <i>Spoke with Site Contractor. Silt fence will be installed on May 31, 2018</i>	May 29, 2018
2018-26	Home Construction: 5616 70th Street West Home demolition and excavation in progress. Perimeter biologs and existing driveway in good condition.	June 1, 2018
2018-25	I-35W Noisewall Repair: I-494 to West 106th Street Construction along wall in progress. No site erosion-related issues observed.	May 31, 2018
2018-24	Westbrook Park Pickleball Court Construction not started.	May 31, 2018
2018-23	69th Street Roundabout Construction Construction not started.	June 1, 2018
2018-22	Edina Promenade Construction not started.	June 1, 2018
2018-21	Normandale D/Bredesen A: Street Reconstruction Street construction in progress. Currently removing existing asphalt. BMPs in place. No issues observed.	June 1, 2018

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 5

2018-20	Normandale Community College Parking Lot Improvements Parking lot excavation and grading in progress. Perimeter silt fence, inlet protection, and rock construction entrance installed and in good condition. No site issues observed.	May 31, 2018
2018-19	Central Park Pickleball Courts Excavation complete. Crews currently placing and leveling sand base. Perimeter BMPs in place. No site issues.	May 28, 2018
2018-18	Normandale Community College, Tunnel and Courtyard Improvements Construction not started.	May 31, 2018
2018-16	Normandale Hills Elementary School Site Improvements Construction not started.	May 30, 2018
2018-14	Pillsbury Truck Storage: 8100 Pillsbury Avenue South Construction not started.	May 31, 2018
2018-13	Home Construction: 4501 Dunham Drive Home demolition in progress. Perimeter silt fence, biologs, and existing concrete driveway construction entrance in good condition.	June 1, 2018
2018-12	Home Construction: 5111 Bluff Circle Home construction in progress. Perimeter silt fence and rock construction improved. No current site issues.	May 30, 2018
2018-10	Friendship Village: SE Quad of 169 & 494 Construction not started.	May 30, 2018
2018-08	Home Construction: 6700 Point Drive Home construction in progress. Perimeter silt fence and biologs in place. <i>Construction entrance partially silted in, will likely need improvement.</i> Left message with Contractor	June 1, 2018
2018-07	Bloomington Self Storage: 9601 Penn Avenue South Building construction in progress. Large soil and material stockpiles on site. Perimeter silt fence, inlet protection, and rock construction entrances in good condition. <i>Minor sediment tracking to street.</i>	May 31, 2018
2018-06	Home Construction: 5221 Meadow Road No demolition/construction activity started.	June 1, 2018

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 6

2018-04	Home Construction: 6005 St. Johns Avenue Home construction in progress. Perimeter biologs and existing driveway in place. No current site issues.	June 1, 2018
2018-03	Home Construction: 5504 Cahill Lane Home construction and landscaping in progress. Perimeter biologs and construction entrance in good condition.	June 1, 2018
2018-02	T.H. 7 Repairs: Baker Road to Louisiana Avenue Construction equipment on site. Barricades in place. No excavation activities currently.	May 28, 2018
2018-01	Home Construction: 6613 Parkwood Road Home construction in progress. Perimeter silt fence and rock construction entrance in good condition.	May 30, 2018
2017-132	T.H. 62 Mill and Overlay: Beach Road to Tracy Avenue Site vegetation not fully established along project.	May 28, 2018
2017-131	T.H. 494 Concrete Barrier: East and West Bush Lake Road Barrier construction in progress. Site BMPs in place. No issues observed.	May 30, 2018
2017-129	Hopkins Pavilion 2018 Improvements: 11000 Excelsior Boulevard Pavilion construction in progress. On-site soil protected with perimeter biologs. Construction entrance in good condition. No tracking to pavement.	May 28, 2018
2017-128	Bridge Reconstruction: I-35W-Cliff Road to 106th Avenue Construction not started.	May 31, 2018
2017-125	American Boulevard Storage and Grading Construction not started.	May 31, 2018
2017-124	Home Construction: 5316 Dundee Road Home construction in progress. Rock construction entrance and perimeter BMP control is in place. No site issues.	June 1, 2018
2017-120	Creek Valley Elementary School Building Addition: 6401 Gleason Road Building construction in progress. Perimeter silt fence and construction entrance in place. No site issues.	May 29, 2018

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 7

2017-117	Green Circle Drive Culvert Replacement: 5643 Green Circle Drive Culvert replacement installation completed. Disturbed soil slopes stabilized with erosion control blankets. Silt curtain remains in stream. No current site issues.	May 29, 2018
2017-116	Concierge Apartment Parking Expansion: 7620 Penn Avenue South Construction no started.	May 31, 2018
2017-115	Home Construction: 6009 Birchcrest Drive Home construction in progress. Perimeter silt fence, biologists, and existing driveway construction in place. No site issues.	June 1, 2018
2017-114	House Demolition: 5200 Dundee Road No current construction activity. Perimeter silt fence and existing driveway in good condition.	June 1, 2018
2017-113	Home Addition: 6116 Eden Prairie Road Home addition in progress. No site issues.	May 30, 2018
2017-112	Home Construction: 6104 Ridgeway Road Home construction in progress. <i>Perimeter silt fence damaged.</i> <i>Left message with Site Contractor to have repaired.</i>	June 1, 2018
2017-111	Willow Creek Road Embankment Repair: 7030 Willow Creek Road Site embankment blankets not fully vegetated. No site issues.	May 28, 2018
2017-110	Southdale Shake Shack: SE Corner, West 66th and France Curb installed. Small soil stockpiles on site. Perimeter biologists in place. No current site issues.	June 1, 2018
2017-109	JC Penney Redevelopment: 200 Southdale Center No current construction/excavation activities.	June 1, 2018
2017-108	Andy's Truck Storage Parking Lot Reconstruction: 8116 Pillsbury Avenue Construction not started.	May 31, 2018
2017-107	Emanuelson Podas Parking Lot Modification: 7705 Bush Lake Road Site grading and landscaping in progress. No current site issues.	May 30, 2018

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 8

2017-106	Site Grading: 9431 Garfield Avenue No current construction activity. Perimeter silt fence partially damaged. Site partially native vegetated.	May 31, 2018
2017-105	Home Construction: 5144 Ridge Trail Home construction in progress. Perimeter silt fence and biologs in place. <i>Minor washouts and tracking to street.</i>	May 30, 2018
2017-104	Bloomington Care Center Parking Lot Expansion Construction not started.	May 31, 2018
2017-103	Pool Construction: 6931 Mark Terrace Circle Not inspected.	
2017-102	Home Construction: 6616 Indian Hills Circle Home construction in progress. Perimeter silt fence, biologs, and rock construction in good condition. No site issues.	May 29, 2018
2017-101	Girard Lake Culvert Replacement: 8401 France Avenue South Not inspected.	
2017-100	Bus Barn Site: 5150 Brookside and 5220 Eden Avenues Building construction in progress. Damaged and missing biologs replaced along street. Street clear of tracked sediment. No current site issues.	June 1, 2018
2017-99	Home Construction: 6219 Westridge Boulevard Home construction in progress. Perimeter silt fence, inlet protection, and rock construction entrance in good condition.	June 1, 2018
2017-98	Home Construction: 5105 Mirror Lake Drive Home construction in progress. Silt fence and construction entrance in good condition. No site issues.	June 1, 2018
2017-95	Home Construction: 5204 61st Street West Home construction in progress. Site graded, perimeter BMPs, and construction entrance in good condition.	June 1, 2018
2017-94	River Valley Crosstown Campus Addition Building construction and excavation in progress. <i>On-site spoils piles not fully protected with perimeter BMP control.</i> <i>Spoke with On-Site Contractor to have repairs made and pavement sediment removed.</i>	May 29, 2018

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 9

2017-92	Valley View Road Trail Expansion No current construction activity.	May 29, 2018
2017-91	Home Construction: 5625 Tracy Avenue Home construction in progress. Perimeter silt fence, biologs, inlet protection, and existing driveway construction entrance in place.	June 1, 2018
2017-90	Home Construction: 5501 Glengarry Parkway Driveway installation in progress. Perimeter silt fence and biologs in good condition.	June 1, 2018
2017-89	Storm Sewer Repair: Site F, West 94th Street and France Avenue Construction complete. Blanket vegetation not established.	May 31, 2018
2017-88	Nine Mile Creek Regional Spur Trails, A & B Trail construction in progress. BMPs in place. No project issues observed.	May 29, 2018
2017-86	Orie Avenue Pipe Replacement Site vegetation not fully established.	May 28, 2018
2017-85	Home Reconstruction: 8840 Southwood Drive Home construction in progress. <i>Biologs overtopped in rear yard.</i> <i>Remove sediment washouts.</i> <i>Install silt fence to capture sediment and stabilize disturbed soils.</i> <i>Spoke with On-Site Contract. He will relay to home owner.</i>	May 30, 2018
2017-82	Demo/Construction: 4228-4230 Valley View Road Home construction complete. Driveway is installed. Biologs partially in place. <i>Disturbed soils not stabilized.</i>	June 1, 2018
2017-81	Home Addition: 5501 Knoll Drive Home construction complete. Driveway forms in place. Perimeter biologs in place for disturbed soils.	May 30, 2018
2017-79	Lone Lake Park Pickleball Courts Court excavation and grading in progress. Perimeter silt fence in good condition.	May 29, 2018
2017-78	Home Addition: 9015 Knox Avenue Home construction complete. Site partially landscaped. No current issues.	May 31, 2018

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 10

2017-77	Bloomington Storm Sewer Maintenance: North Myr Marsh	
	A. Not inspected.	
	B. Not inspected	
	C.	
	D. Not inspected.	
	E. Site vegetation not fully established	May 31, 2018
	F. Construction complete. Blanket vegetation not established.	May 31, 2018
	G. Construction complete. <i>Project will be removed from inspection list.</i>	May 31, 2018
	H. Site vegetation not fully established.	May 31, 2018
2017-74	Home Reconstruction: 5809 South Drive	June 1, 2018
	Home construction in progress. Perimeter silt and biologs in good condition. No site issues.	
2017-72	Restoration Hardware: 6953 Southdale Road	June 1, 2018
	Construction not started.	
2017-69	Normandale Office Park Paving: 8201 Norman Center Drive	May 30, 2018
	Paving project complete. <i>Project will be removed from inspection list.</i>	
2017-65	Home Reconstruction: 5531 Eden Prairie Rd.	May 28, 2018
	Site landscaping in progress. Perimeter BMPs removed.	
2017-64	Home Reconstruction: 5019 Knob Hill Road	June 1, 2018
	Home construction in progress. Perimeter BMPs and rock construction entrance in good condition.	
2017-61	Wentworth Storage Lot: 8824-8870 Wentworth Avenue South	May 31, 2018
	Construction not started.	
2017-60	Poplar Bridge Elementary Mechanical Improvements, 8401 Palmer Avenue	May 30, 2018
	Site vegetation established. <i>Project will be removed from inspection list.</i>	

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 11

2017-59	Edina Mill and Overlay	
	Gleason Area: Vegetation not fully established along project area.	May 29, 201
	Hansen Road: Vegetation established. <i>Project will be removed from inspection list.</i>	June 1, 2018
	Valley View Road: Vegetation not fully established along street.	June 1, 2018
	West 66th Street: Site vegetation not fully established.	May 30, 2018
2017-58	Home Construction: 5705 View Lane	May 30, 2018
	Home construction in progress. Spoils piles on site. Perimeter silt fence and construction entrance in good condition.	
2017-57	Home Construction: 5705 View Lane	May 30, 2018
	Home construction complete. Driveway installed. Site not landscaped. Perimeter silt fence in place.	
2017-55	Home Reconstruction: 6209 Crest Lane	June 1, 2018
	Home construction in progress. Perimeter biologs and rock construction in place. No site issues.	
2017-50	Home Reconstruction: 5630 Glen Avenue	May 28, 2018
	Site landscaping in progress. Driveway paved. No current site issues.	
2017-46	66th Street and York Ave. Street Improvements	May 31, 2018
	Site vegetation not fully established.	
2017-45	Alaskan Fur Parking Lot Expansion, 7800 Normandale Blvd.	May 30, 2018
	Site vegetation not fully established.	
2017-44	CenterPoint Energy Gas Main Replacement, Old Shakopee, Penn, and Morgan	May 31, 2018
	Construction complete. Site restored. <i>Project will be removed from inspection list.</i>	
2017-43	Double Tree Hotel Parking Lot Expansion, 7800 Normandale Blvd.	May 30, 2018
	Site vegetation not fully established.	
2017-29	2017-102 PMP Street Maintenance Project, Mill & Overlay: East 86th Street	

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 12

2017-28	Hennepin County South Suburban Court Relocation, 1800 Old Shakopee Rd. Construction not started.	May 31, 2018
2017-27	I-35W and West 86th Street Bridge Replacement Disturbed slopes and ditch banks stabilized with erosion control blankets. Minimal vegetation established. No erosion-related issues observed.	May 31, 2018
2017-26	Home Construction: 5124 West 60th Street Home construction in progress. Perimeter silt fence and biologs in place. No site issues.	June 1, 2018
2017-19	Christ Presbyterian Church Addition Site landscaping in progress. Perimeter biologs in place. No current issues.	June 1, 2018
2017-18	I-494 and East Bush Lake Road: Road and Bridge Construction Bridge and road construction in progress. Large soil stockpiles on site, protected with perimeter silt fence and biologs. Inlet protection in place. No erosion-related issues observed.	May 30, 2018
2017-16	Home Reconstruction: 6608-6612 Indian Hills Rd. Home construction in progress. Damaged silt fence backed up with perimeter biologs. <i>Minor tracking to street.</i>	May 29, 2018
2017-13	2017 Hopkins Street and Utility Projects 9th Avenue: Boulevard vegetation not fully established 5th Avenue/7th Street: Former staging area graded, leveled, and seeded. Perimeter BMPs removed. No current site issues. 2nd Street Areas:	May 29, 2018 May 29, 2018
2017-11	Rize @ Opus Apartment Building, 1010 Bren Road Building construction in progress. <i>Damaged perimeter silt fence needs repair.</i> <i>Remove sediment in parking area.</i> Left message with Site Contractor.	May 29, 2018
2017-10	Peace Lutheran Church Site vegetation not fully established.	May 29, 2018

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 13

2017-09	Baker Road Mini Storage Building construction in progress. Curb partially installed. Spoils piles remain on site. <i>Repair damaged and overtopped silt fence in rear area of property.</i> Left message with Site Contractor.	May 28, 2018
2017-08	Pump and Meter Building Addition, 11303 Excelsior Blvd. No current construction activity. Culvert materials staged on site.	May 28, 2018
2017-07	Seagate Building A Switch Gear Pad Site vegetation not fully established.	May 30, 2018
2017-05	Home Construction: 5508 Knoll Drive Home construction complete. Site landscaping also nearly completed.	May 30, 2018
2017-04	Lift Station Rehab. 8th Street South and South 6th Avenue Site vegetation not fully established.	May 29, 2018
2017-02	Pillsbury Property Parking Lot Reconstruction, 8100 Pillsbury Ave. S. Site vegetation not fully established.	May 31, 2018
2017-01	Home Reconstruction: 5901 Olinger Road Home construction complete. Rock construction driveway in place. Yard graded, but not sodded or seeded.	May 29, 2018
2016-142	International Spanish Language Academy Redevelopment, 5959 Shady Oak Rd. Construction not started.	May 29, 2018
2016-141	Home Construction: 5203 Duncraig Road Home construction complete. Driveway installed. Site landscaping not started. <i>Stabilize disturbed soils or replace BMPs.</i> Left message with Site Contractor.	June 1, 2018
2016-137	Edina Medical Office, 7700 France Avenue South Parking lot paving in progress. Inlet protection in place near areas of unvegetated disturbed soils. No current site issues.	May 31, 2018
2016-134	#52643 Edina Small Cell Fiber Optic Line Installation No construction activity.	May 30, 2018

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 14

2016-130	Home Reconstruction: 5812 Hidden Lane No construction activity.	June 1, 2018
2016-129	Carlson Print Parking Lot Expansion, 7490 Golden Triangle Retaining wall construction in progress. Perimeter biologs in place. <i>Minor sediment washouts to parking area.</i>	May 29, 2018
2016-119	Braemar Golf Course Renovation Course landscaping and grading in progress. Large areas seeded. Various stages of vegetation establishment. <i>Several areas of washouts contained on site.</i> <i>May need blankets or tackifier to stabilize.</i>	May 30, 2018
2016-118	Toro Phase 3—American Boulevard and Penn Avenue Pond bank vegetation not fully established.	May 31, 2018
2016-112	Street Maintenance Projects (103-112)	
2016-111	Street Maintenance Projects (103-112)	
2016-109	Street Maintenance Projects (103-112)	
2016-107	Street Maintenance Projects (103-112)	
2016-106	Street Maintenance Projects (103-112)	
2016-105	Street Maintenance Projects (103-112)	
2016-104	Street Maintenance Projects (103-112)	
2016-103	Street Maintenance Projects (103-112)	
2016-102	Home Construction—6358 Coteau Trail Not inspected.	

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 15

2016-101	Home Construction—6005 Pine Grove Road No current construction activity.	May 30, 2018
2016-100	Williston Woods Development, Williston Rd. and Excelsior Blvd. Home construction in progress. Perimeter silt fence and construction in good condition. No site issues.	May 28, 2018
2016-99	5901 Lincoln Drive Residences Building construction and landscaping activities in progress. Perimeter silt fence, biologs, and inlet protection in good condition. No current site issues observed.	May 28, 2018
2016-97	Cahill Storage—7625 Cahill Road Limited renovations in progress. Small excavation on site. No issues.	May 30, 2018
2016-96	Edina Schools Transport Facility—7600 Metro Boulevard Project complete. Site restored. <i>Project will be removed from inspection list.</i>	May 28, 2018
2016-93	Gateway Pointe. SE Quad—York Avenue and West 66th Street Building construction in progress. Perimeter silt fence, inlet protection, and rock construction entrance in good condition. No tracked sediment to street.	May 31, 2018
2016-92	Edina Retail—3901 West 70th Street Building and parking lot construction in progress. No current site issues observed.	June 1, 2018
2016-89	Camp Edenwood Respite Cabin Site vegetation not fully established.	May 28, 2018
2016-85	Verizon Telecommunications Tower construction, 6752 Shady Oak Rd. Construction not started.	May 29, 2018
2016-84	Prestige School Construction, 14625 Excelsior Blvd. Pond vegetation not fully established.	May 28, 2018
2016-72	Braemar Cold Storage Site Storage Improvements—7600 Braemar Boulevard Site slope vegetation not fully established.	May 30, 2018

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 16

2016-71	Homewood Suites, Hotel—66th Street and York Avenue (SW Quad) Building construction in progress. Perimeter silt fence and inlet protection in good condition. No site issues.	May 31, 2018
2016-63	T.H. 169, Nine Mile Creek Bypass Site slope and bank vegetation not fully established. No site issues.	May 29, 2018
2016-43	Climatech Building Renovation, 6950 Washington Avenue <i>Pond bank slopes continuing to erode.</i> <i>Bank vegetation <30% along south area of pond.</i>	May 29, 2018
2016-40	Highlands Elementary School, 5505 Doncaster Way Building construction and site excavation in progress. Perimeter silt fence and biologs in place. No sediment tracking observed.	June 1, 2018
2016-39	Home Construction: 6609 Blackfoot Pass Home construction in progress. <i>Minor sediment tracking to road.</i> <i>Perimeter biologs will need replacement as vehicles continue to drive over it.</i>	May 29, 2018
2016-37	Two MarketPointe Ramp Expansion, 4700 78th St. Site vegetation not fully established.	May 31, 2018
2016-36	Normandale Improvements, 9-Mile Creek to Poplar Bridge Rd. Trail construction, median fill installation, and disturbed soil grading and landscaping in progress. No current project issues observed.	May 30, 2018
2016-22	Home Construction: 9000 Veness Rd. Site vegetation not fully established.	May 29, 2018
2016-20	Minnetonka Corporate Expanded parking, 5900 Clearwater Dr. Water retention pond slopes <30% vegetated.	May 28, 2018
2016-17	CenterPoint Energy, Normandale Boulevard Improvements Construction activities in progress.	May 30, 2018
2016-08	Tracy Avenue and Valley View Road Intersection Improvements Site vegetation not fully established.	June 1, 2018
2016-05	Edina High School Redevelopment—6754 Valley View Road Site vegetation not fully established.	May 29, 2018

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 17

2016-04	Chief's Towing Parking Lot Reconfiguration— 9604/9608 Humboldt Avenue	May 31, 2018
	Vegetation on slopes not fully established.	
2015-130	Lupient Chevrolet Parking Lot Reconfiguration— 1601 Southtown Drive	May 31, 2018
	Construction not started.	
2015-119	Home Construction—9044 West Bush Lake Road	May 29, 2018
	Site vegetation not fully established.	
2015-108	Norman Pointe Residential—5650 American Blvd. West	May 30, 2018
	Minor site construction in progress. No site issues.	
2015-91	Home Reconstruction—9243 Green Briar Road	May 30, 2018
	No construction activity.	
2015-89	Lower Valley Maintenance	
	Not inspected.	
2016-87	Blake Woods Subdivision	May 30, 2018
	Curb installed. Street paved. Raingarden installed along street. Vegetation emerging from disturbed soils seeding. No current construction activities.	
2015-84	Hyland Hills Ski Jump Improvements	May 30, 2018
	No current construction activity. Natural site vegetation partially established providing adequate erosion-control for sections of damaged silt fence. No erosion-issues observed.	
2015-80	Richfield Farm/Sheridan Villas—Sheridan & 76th Street	May 31, 2018
	Site vegetation not fully established.	
2015-76	NAPA Auto Addition—1842 Main Street	May 28, 2018
	Sol recently added to slope washouts on pond banks. Site vegetation not fully established.	
2015-66	Double Tree Parking Lot Reconfiguration—7800 Normandale	May 30, 2018
	Site vegetation not fully established.	
2015-53	Nine Mile Creek Regional Trail-East and West Segments	June 1, 2018
	Trail construction in progress. BMPs in place. No site issues observed.	
2015-29	New Home Construction—6600 Old Shady Oak Road	May 29, 2018
	No construction activity.	

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 18

2015-28	7101 France Avenue Building C Slope vegetation not established. <i>Insufficient topsoil for plant growth. Will likely need additional topsoil and reseeded.</i>	June 1, 2018
2015-16	Home Construction—6116 Hansen Road No construction activity.	June 1, 2018
2014-98	Margaret A. Cargill Philanthropies—6889 Rowland Rd. Site vegetation not fully established.	May 29, 2018
2014-91	6th Avenue Demolition Site graded, leveled, and seeded. BMPs removed. No current erosion-related issues.	May 28, 2018
2014-87	Pentagon South Demolition—SW Quadrant of West 77th Street and Computer Avenue No current construction activity.	May 30, 2018
2013-93	Home Construction-Willow Wood Road and Bryant Lake Drive Construction not started.	May 28, 2018
2012-41	Carlson Print Parking Lot Expansion—6455 Flying Cloud Drive No construction activity.	May 28, 2018
2008-23	The Enclave at Old Shady Oak	May 29, 2018
	6300 Montee Dr.: Home construction in progress. Perimeter BMPs in place. No site issues.	May 29, 2018
	6276 Montee Dr.: No current construction activity. <i>Damaged or missing perimeter control needs repair. Remove sediment washed into cul-du-sac. Left message with Site Contractor</i>	May 29, 2018
	6268 Montee Dr.:	
	6232 Coteau Trail: Not inspected.	
	6240 Coteau Trail: Not inspected.	
	6334 Coteau Trail: No current construction activity. Natural vegetation covering most of site.	May 29, 2018
	6358 Coteau Trail	
	6331 Bellevue Lane: No current construction activity.	May 29, 2018
	6339 Bellevue Lane:	

To: Nine Mile Creek Watershed District—File
From: Kim Johannessen
Subject: May 28, through June 1, 2018—Erosion Inspection
Date: June 5, 2018
Page: 19

**2008-19
(REVISED)**

The Luxembourg Apartments

May 30, 2018

*Pond bank vegetation not fully established.
Material stockpile in parking area requires perimeter control.
Left message with Site Contractor*

**Inspection
Requested by
Concerned Citizen**

5324 Blake Road Home Development *This is Permit 2016-87*

Please contact me at 952.832-2686 or KJohannessen@barr.com if you have questions on the projects listed above or any additional items that need to be addressed for the erosion control inspections.