

MEMO

To: Nine Mile Creek Watershed District Board of Managers

From: Lauren Foley

Date: 14 August 2019

Permit Inspection Report

Summary

This month ended with a lot of completed projects (and removed from inspection queue), likely as a results of months of good weather to finish up remaining work. There was also a high compliance rate.

- Number of inspections: 43
- Number of sites removed: 15
- Number of sites to remain in queue with no issues observed: 15
- Number of sites with action or follow up required: 4
- Number of sites with issue not requiring action (vegetation getting established, etc.): 2
- Number of sites with no activity or project not started: 5

Inspections

Sites with Significant Issue(s) Observed Requiring Follow Up							
Permit #	Address	Туре	Summary of Results	Communication			
2018-	125 Monroe Ave S, Hopkins	Public	East side silt fence near outlet overwhelmed	Sent report to applicant			
137			by sediment				

Sites with Minor Issue(s) Observed Requiring Follow Up							
Permit Number	Address	Туре	Summary of Results	Communication			
2018- 128	6100 Ridgeway Rd, Edina	SFH	Silt fence loose adjacent to street	Sent report to applicant			
2018- 140	France Ave Trail W 84 th to Old Shakopee Rd, Bloomington	Linear	Missing inlet protection north of 90 th St.	Sent report to applicant. Fixed 8/13 per applicant.			
2019-66	8701 Lyndale Ave S, Bloomington	Commercial	Need street sweeping and tightened silt fence along Harriet Ave	Sent report to applicant			

Follow Up Inspections on Existing Issues							
Permit Number	Address	Туре	Summary of Results	Communication			
2018-	7800-7850 Dupont Ave S,	Commercial	Issues from last inspection fixed (degraded	None needed			
113	Bloomington		const. exit and street tracking east side)				

Totals

All values are estimates

Approximately 195 open permits with potential for activity

- Approximately 108 with activity
- Approximately 87 without activity