



MEMO

To: Nine Mile Creek Watershed District Board of Managers

From: Lauren Foley

Date: 12 June 2019

Permit Inspection Report

Summary

This month's focus was to target projects that we suspected were complete and stabilized and remove them from the inspection list. Repetitive unexpected issue was a lack of perimeter control installation.

- Number of sites inspected: 23
- Number of sites removed: 10
- Number of sites to remain in queue with no issues observed: 6
- Number of sites with action or follow up required: 7

Inspections with Significant Issue(s) Observed				
Permit #	Address	Type	Summary of Results	Communication
2017-113	6116 Eden Prairie Rd, Edina	SFH	Yard is mainly exposed soils with no stabilization	Sent report to applicant

Follow Up Inspections on Existing Issues

Permit Number	Address	Type	Summary of Results	Communication
2018-77	9020 Bush Lake Rd, Bloomington	SFH	Perimeter issues and stockpile issues corrected	None needed

Sites Needing Follow Up Inspections

Permit Number	Address	Type	Summary of Results	Communication
2017-113	6116 Eden Prairie Rd, Edina	SFH	Yard is mainly exposed soils with no stabilization	Sent report to applicant
2018-27	6453 McCauley Terrace, Edina	SFH	Stabilization (grass seed) is patchy but progressing	None needed
2018-81	15915 Excelsior Blvd, Minnetonka	Commercial	Stabilization complete but BMPs need removal	Sent report to applicant
2018-107	9401 Bloomington Ferry Rd, Bloomington	Public	Inspect in future to ensure seed has taken	None needed
2018-108	9550 Lyndale Ave S, Bloomington	Commercial	Missing inlet and perimeter protection	Sent report to applicant
2018-113	7800-7850 Dupont Ave S, Bloomington	Commercial	East construction exit is degraded with excessive street tracking	Sent report to applicant
2018-116	4637 Shady Oak Rd, Minnetonka	Commercial	Perimeter control has been removed	Sent report to applicant