



MEMO

To: Nine Mile Creek Watershed District Board of Managers

From: Lauren Foley

Date: March 9, 2021

Permit Inspection Report

Summary

This month's inspections were the first where the route was determined with assistance from MS4 Front's map of permitted sites.

- Number of inspections: 21
- Number of sites removed: 6
- Number of sites to remain in queue with no issues observed: 8, 4 sent emails about imminent erosion risks
- Number of follow up inspections: 0
- Number of projects where no activity visible: 1
- Number of inspections with project not started: 4
- Number of inspections with issues observed: 1
- Number of inspections by request: 1 (conclusion is no permit needed)

Inspections

Sites with Issue(s) Observed				
Permit Number	Address	Type	Summary of Results	Communication
2021-130	6201 St Albans Cir, Edina	Single Family Home	Rock entrance not spread, street tracking of sediment, need inlet protection, biologs in imminent threat of overtopping	Inspection report sent to permit contact

Follow-Up Inspections				
Permit Number	Address	Type	Summary of Results	Communication
None				

Totals

All values are estimates

Approximately 205 open permits with potential for activity

- Approximately 125 with activity
- Approximately 80 without activity