

Nine Mile Creek Abbreviated Site Inspection Report
October 29, 2018 through November 2, 2018

Permit #	Project Name	Date of Inspection	Observations	Status
2018-88	Home Construction: 6412 Indian Hills Rd.	2-Nov-2018	Home construction in progress. <i>Repair damaged perimeter, silt fence, and install inlet protection at street culver.</i> Contractor is in contact with City to determine sewer/stormwater issues.	Concerns noted for follow-up.
2018-73	CenterPoint Energy Utility Installation, Countryside Rd:	1-Nov-2018	Utility and street construction complete. Project will be removed from inspection list.	Project will be removed from inspection list.
2018-61	Kidde Academy: 7711 Computer Avenue	2-Nov-2018	Pond vegetation not fully established. Biologs remain at base of pond. Standing water remains in pond.	Vegetation not fully established. Concerns noted for follow-up.
2018-50	Bloomington Mill & Overlay: Brookside Area	31-Oct-2018	Construction and restoration complete. Project will be removed from inspection list.	Project will be removed from inspection list.
2018-49	NE Penn Stormwater Storage Project	31-Oct-2018	Street, curb, and excavation construction activities in progress. On-site Contractor will have additional inlet protection installed in street locations and install perimeter BMPs along temporary haul road.	Concerns noted for follow-up.
2018-47	Woodhill Road Reconstruction	30-Oct-2018	Street construction in progress. Curb installed, road bed and boulevard grading partially completed. Several soil stockpiles on site will be removed with 24 hours and sediment discharge to pond will be removed before sidewalk completion, per on-site Contractor.	Concerns noted for follow-up.
2018-36	Street Improvements: 108 th Street	31-Oct-2018	Street construction and restoration complete. Project will be removed from inspection list.	Project will be removed from inspection list.
2018-34	86 th Street	31-Oct-2018	Street construction and restoration complete. Project will be removed from inspection list.	Project will be removed from inspection list.
2018-28 d)	Edina Street Mill and Overlay Projects: d) Countryside C	1-Nov-2018	Street construction and restoration complete. Project will be removed from inspection list.	Project will be removed from inspection list.
2018-28 g)	Edina Street Mill and Overlay Projects: g) West 66 th Street	1-Nov-2018	Street construction and restoration complete. Project will be removed from inspection list.	Project will be removed from inspection list.
2018-28 m)	Edina Street Mill and Overlay Projects: m) Edina Industrial/Normandale	2-Nov-2018	Street construction and restoration complete. Project will be removed from inspection list.	Project will be removed from inspection list.
2018-21	Normandale D/Bredesen A: Street Reconstruction	1-Nov-2018	Street construction and restoration complete. Project will be removed from inspection list.	Project will be removed from inspection list.
2018-20	Normandale Community College Parking Lot Improvements	31-Oct-2018	Parking lot construction and restoration complete. Project will be removed from inspection list.	Project will be removed from inspection list.
2017-132	T.H. 62 Mill and Overlay: Beach Road to Tracy Avenue	2-Nov-2018	Street construction in progress. Previously disturbed soils graded and seeded. <i>Several soil stockpiles at 62/Gleason laydown area need perimeter control.</i> Left message with Site Supervisor.	Concerns noted for follow-up.
2017-105	Home Construction: 5144 Ridge Trail	1-Nov-2018	Home construction complete. Contractor on site to remove sediment from infiltration basin and stabilize slopes and repair damaged perimeter silt fence along adjacent property's disturbed soils.	Concerns noted for follow-up.

Nine Mile Creek Abbreviated Site Inspection Report
October 29, 2018 through November 2, 2018

Permit #	Project Name	Date of Inspection	Observations	Status
2017-95	Home Construction: 5204 61 st Street West	1-Nov-2018	Home construction in progress. Small spoil pile on site in front yard. Install BMPs along disturbed soil/spoil pile along street. Left message with on-site Contractor.	Concerns noted for follow-up.
2017-94	River Valley Crosstown Campus Addition	30-Oct-2018	Building construction and landscaping activities in progress. Site BMPs in place. Tracked sediment in parking area will be removed within 24-48 hours by on site Contractor.	Concerns noted for follow-up.
2017-64	Home Reconstruction: 5019 Knob Hill Road	1-Nov-2018	Driveway and retention wall installed. Silt fence checks installed on slope to prevent further sediment washouts. <i>Sediment deposited in infiltration basin will need to be removed before final stabilization.</i> Contacted site Manager to have repairs/improvements completed.	Concerns noted for follow-up.
2016-141	Home Construction: 5203 Duncraig Road	1-Nov-2018	Steep slopes along sides and rear of site need additional stabilization. Existing biologs inadequate to prevent additional sediment washouts to wetland. Previously deposited sediment needs to be removed from wetland. Contacted project manager to have issues corrected.	Concerns noted for follow-up.
2016-100 5431	Williston Woods Development, Williston Rd. and Excelsior Blvd.	30-Oct-2018	5431: Home construction in progress. <i>Damaged perimeter silt fence needs repair/replacement.</i> Contractor will have repairs made within 48 hours.	Concerns noted for follow-up.
2016-93	Gateway Pointe. SE Quad—York Avenue and West 66 th Street	31-Oct-2018	Building construction in progress. Perimeter silt fence, biologs, inlet protection and rock construction entrance in good conditions. Reminded on site Contractor to remove tracked sediment on street daily, or as needed.	Concerns noted for follow-up.
2016-37	Two MarketPointe Ramp Expansion, 4700 78 th St.	31-Oct-2018	Site vegetation established. Project will be removed from inspection list.	Project will be removed from inspection list.
2014-87	Pentagon South Demolition—SW Quadrant of West 77 th Street and Computer Avenue	2-Nov-2018	Site grading and excavating in progress. Permit #2018-97 replaces this permit.	Project will be removed from inspection list.
2008-23 6276 Montee	The Enclave at Old Shady Oak: 6276 Montee Drive	30-Oct-2018	Home construction in progress. Damaged perimeter silt fence and biologs need repair/replacement. Left message with site Contractor to have repairs made.	Concerns noted for follow-up.